

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN FRANCISCO BAY REGION

ORDER NO. 77-90

NPDES NO. CA0037711
TO ADOPT A REVISED COMPLIANCE TIME
SCHEDULE AND REQUIREMENTS FOR:

CITY OF MILL VALLEY
MARIN COUNTY

The California Regional Water Quality Control Board, San Francisco Bay Region,
finds that:

1. The Regional Board, on December 17, 1974, adopted Order No. 74-207 (NPDES Permit No. CA0037711) prescribing waste discharge requirements and compliance time schedules for the City of Mill Valley.
2. The Regional Board, on May 4, 1976, adopted Order No. 76-40 prescribing revised waste discharge requirements and compliance time schedule for the City of Mill Valley.
3. The City is participating in the Marin-Sonoma Subregional Agency Study to comply with certain effluent and receiving water limitations and the prohibition against discharge at the present near-shore location contained in Order No. 74-207. Completion of a draft Environmental Impact Report/Environmental Impact Statement has been delayed due to delays in promulgation of specifications for Bay studies by the State Board and the adoption of the Marsh Policy by this Regional Board.
4. This project involves the continued operation of a publicly-owned facility to provide sewerage service with negligible or no expansion of use beyond that previously existing. Consequently, this project will not have a significant effect on the environment based upon the exemption provided in Section 15101, Title 14, California Administrative Code.
5. The Board has notified the discharger and interested agencies and persons of its intent to prescribe revised requirements for the City of Mill Valley.
6. The Board, in a public meeting, heard and considered all comments pertaining to this discharge.

IT IS HEREBY ORDERED that:

- A. The following interim effluent limitations are added to Order No. 74-207.

Effluent Limitation A. 12

| <u>Constituents</u> | <u>Units</u> | <u>30-Day Average</u> | <u>Daily Maximum</u> |
|---------------------|--------------|---------------------------|--------------------------|
| a. BOD | lbs/day | 992 | 1,980 |
| | mg/l | 20 | 40 |
| b. Suspended Solids | lbs/day | 1,240 | 2,480 |
| | mg/l | 25 | 50 |

The discharger shall comply with these interim limitations upon adoption of this Order and prior to completion of new treatment and disposal facilities.

B. Order Nos. 74-207 and 76-40 are amended to read as follows:

Provision D.2.b.

Compliance with Effluent Limitations A.1.a, c; A.6; Receiving Water Limitation B.2.d; and Discharge Prohibition C.1:

| <u>Task</u> | <u>Completion Date</u> | <u>Report of Compliance Due</u> |
|--|------------------------|-------------------------------------|
| Publish completed Draft EIR/EIS and draft facilities plan | October 1, 1977 | October 15, 1977 |
| Hold public hearing on Draft EIR/EIS | November 15, 1977 | November 30, 1977 |
| Complete institutional arrangements necessary to implement facilities plan | January 1, 1978 | January 15, 1978 |
| Publish and submit Final EIR/EIS | May 1, 1978 | |
| Submit Project Report and Step II grant application to SWRCB and this Board | May 1, 1978 | |
| Submit necessary applications for NPDES permits including time schedule for design and construction of facilities to meet requirements | May 1, 1978 | |

Provision D.10.

This Order expires on December 1, 1978, and the Discharger must file a Report of Waste Discharge in accordance with Title 23, California Administrative Code, not later than 180 days in advance of such date as application for issuance of new waste discharge requirements.

I, Fred H. Dierker, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on July 19, 1977.

FRED H. DIERKER
Executive Officer